

Number	20-001008-PR01 (NW-H01-09-en-01)
Owner	Ramsauer GmbH & Co. KG Sarstein 17 4822 Bad Goisern Austria
Product	Insulating glass unit
Designation	System: UNITOP (UNICLASSIC)
Details	Overall dimensions (W x H) 352 mm x 502 mm; Glass configuration 4 mm / 12 mm / 4 mm; Spacer: Manufacturer Rolltech A/S, - Hjøring; Designation Chromatech Plus; Material Stainless steel; Secondary sealant: Manufacturer Ramsauer GmbH & Co. KG, - Bad Goisern; Designation 2K 670; Material Basis silicone; Primary sealant: Manufacturer Kömmerling Chemische Fabrik GmbH, - Pirmasens; Designation GD 115; Material Basis Polyisobutylene
Special features	

Result

Long term test method according to EN 1279-2 :2018-07



Requirement: fulfilled

ift Rosenheim

16.09.2020



Miriam Keill, B.Eng.
Deputy Head of Testing Department
Material Testing



Maximilian Weiß, B.Sc.
Operating Testing Officer
Material Testing

Basis *)


EN 1279-2 :2018-07

EN 1279-3:2018-07

*) and corresponding national versions
(e.g. DIN EN)

Test report: 20-001008-PR01 PB-H01-09-de-01

Representation



Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: FF5-2F371