




Number	20-001008-PR02 (NW-K02-09-en-01)	
Owner	Ramsauer GmbH & Co. KG Sarstein 17 4822 Bad Goisern Austria	
Product	Secondary sealant for insulating glass units	
Designation	Shipping name: 2-component sealant 670	
Details	Manufacturer Ramsauer GmbH & Co. KG, 4822 - Bad Goisern; Material Based on silicone; Color Black	
Special features	-/-	
Result**		
	5.3 Adhesion	The requirements of EN 1279-4:2018-07 chapter 5.3, stress-strain behaviour, are fulfilled
	5.5.2 Moisture vapour transmission rate	MVTR _(lowest single value) = 11.6 g _{H2O} /(m ² *d)
	5.5.3 Gas permeation rate	GPR _(lowest single value) = 31.4 g/(m ² *d)

Basis *)

EN 1279-4:2018-07
EN ISO 11358-1:2014-07
EN ISO 10563:2017-09
EN ISO 1183-1:2019-04
*) and corresponding national versions (e.g. DIN EN)
Test report: 20-001008-PR02 (PB-K02-09-de-01)

Instructions for use

***) Decision rule: For the conformity assessment, the determined measurement results were assumed to be error-free values.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

Notes on publication


The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

21.05.2021



Michael Freinberger, Dipl.-Ing. (FH)
Head of Testing Department
Material Testing



Jennifer Seyfang, Dipl.-Ing. (FH)
Operating Testing Officer
Material Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 283-13D50